



# Certificate of Compliance

**Certificate:** 1905817

**Master Contract:** 201383

**Project:** 2146655

**Date Issued:** March 6, 2009

**Issued to:** A-T Controls Group Inc.

11363 Deerfield Rd  
Cincinnati, OH 45242  
USA  
Attention: Patrick Combs

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** James Cotton

**Authorized by:** David Schaefer, Manager of Certification Services

## **PRODUCTS**

**CLASS 3211 87** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - Certified to US Standards

**CLASS 3211 07** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Enclosures for WE Series valve actuators rated Type 4 and 4X.

Notes:

**NOTES**



**Certificate:** 1905817

**Master Contract:** 201383

**Project:** 2146655

**Date Issued:** March 6, 2009

---

Certification is independent of the internal components of the actuator valve; and thus, can be applied to cover other similar actuator products in the weather resistant family, under the discretion of CSA International.

**APPLICABLE REQUIREMENTS**

UL Standard 50	Twelfth Edition	Enclosures for Electrical Equipment
CAN/CSA C22.2 No 94.1-07 Environmental Considerations	September 04, 2007	Enclosures for Electrical Equipment, Non-
CAN/CSA C22.2 No 139	March 1982	Electrically Operated Valves
UL Standard 429	Fifth Edition	Electrically Operated Valves

**MARKINGS**

See Descriptive Report