



Certificate / Certificat Zertifikat / 合格証

ATC 1610008 C001

exida hereby confirms that the:

TS2 & TS3 Trunnion Mounted Ball Valves

**A-T Controls Inc.
Stafford, TX - USA**

The manufacturer
may use the mark:



Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{AVG} and Architecture Constraints
must be verified for each application**

Revision 2.0 February 24, 2020

Surveillance Audit Due
April 1, 2023

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:


The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#1004




Evaluating Assessor


Certifying Assessor

ATC 1610008 C001

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{AVG} and Architecture Constraints
must be verified for each application**

Systematic Capability :

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT¹

Application	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke, Clean Service	0	0	0	462
Tight Shut-Off, Clean Service	0	0	0	1020
Open on Trip, Clean Service	0	122	0	340
Full Stroke, Severe Service	0	0	0	855
Tight Shut-Off, Severe Service	0	0	0	1914
Open on Trip, Severe Service	0	218	0	636

¹ FIT = 1 failure / 10⁹ hours

² PVST = Partial Valve Stroke Test of a final element Device

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: ATC 16/10-008 R002 V2R1 (or later)

Safety Manual: IOM08067, 2017/03/07

TS2 & TS3 Trunnion
Mounted Ball Valves



80 N Main St
Sellersville, PA 18960