



Certificate of Compliance

Certificate: 80037768

Master Contract: 201383

Project: 80037768

Date Issued: 2020-10-08

Issued To: A-T Controls, Inc.
9955 International Blvd
Cincinnati, Ohio, 45246
United States

Attention: Pete Vezey

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Vajira Sarathchandra
Vajira Sarathchandra

PRODUCTS

CLASS - C337110 - VALVES (GAS) Lever Operated Non-Lubricated Shutoff

Manually Operated Ball Valves for gas applications

<u>Model</u>	<u>Diameter Inlet x Outlet (inches)</u>
F88 Series 3 Piece Ball Valve	1/4", 3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3"
F90 Series Split Body Flanged Ball Valve	1/2", 3/4", 1", 1-1/2", 2", 2-1/2", 3", 4"
93 Series Split Body Flanged Ball Valve	6"

Maximum Operating Pressure: 125 PSI
Temperature Range: -30°C to 65°C (-22°F to 149°F)

APPLICABLE REQUIREMENTS

CSA 3.16-2015

Lever Operated Non-Lubricated Gas Shut-Off Valves



Supplement to Certificate of Compliance

Certificate: 80037768

Master Contract: 201383

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80037768	2020-10-08	Original Certification to CSA 3.16-2015. 93 Series flanged ball Valve (6"), F88 Series 3-piece ball valves in various end connections (1/4", 3/8", 1/2", 3/4", 1", 1-1/4", 1-1/2", 2", 2-1/2", 3"), F90 Flanged ball valves (1/2", 3/4", 1", 1-1/2", 2", 2-1/2", 3", 4")